

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 13-51-08299  
Name of Facility: Silver Bluff Elem.  
Address: 2609 SW 25 Avenue  
City, Zip: Miami 33133  
  
Type: Public Schools  
Owner: M-DCSB Food and Nutrition  
Person In Charge: Telio M. Gutierrez Phone: 305 856-9157  
PIC Email: tmgutierrez@dadeschools.net

**Correct By: Next Inspection**  
**Re-Inspection Date: None**

**Inspection Information**

Purpose: Routine  
Inspection Date: 3/1/2019

Begin Time: 09:00 AM  
End Time: 11:00 AM

**Additional Information**

FEMALES ..... CENSUS ..... 0  
MALES .....

*This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.*

**Violation Markings**

SCHOOL SANITATION	<b>IN</b> 11. Group Toilet Rooms	<b>IN</b> 21. Pest Control
<b>IN</b> 1. School Site	<b>IN</b> 12. Toilet Facilities	SAFETY
<b>IN</b> 2. Playground, Equip & Athletic Fields*	<b>IN</b> 13. Handwashing Facilities	<b>IN</b> 22. First Aid Kit
<b>IN</b> 3. Athletic & Playground Equipment	<b>IN</b> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<b>IN</b> 15. Shower Facilities	<b>IN</b> 23. Sanitizers
<b>IN</b> 4. Construction	<b>IN</b> 16. Showers Water Temperatures	<b>IN</b> 24. Changing Station & Mats
<b>IN</b> 5. Maintenance & Repair	WATER SUPPLY	<b>IN</b> 25. Hand Sink
<b>IN</b> 6. Lighting Standards	<b>IN</b> 17. Approved Source	<b>IN</b> 26. Garbage Can
<b>IN</b> 7. Heating, Ventilation, A/C Standards	<b>OUT</b> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<b>IN</b> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<b>IN</b> 27. Animal Maintenance/Aggressive
<b>IN</b> 9. Mechanical Ventilation	<b>IN</b> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<b>IN</b> 20. Solid Waste	<b>IN</b> 28. Maintenance/Complaint
<b>IN</b> 10. Provided/Accessible/Separation	PEST CONTROL	<b>IN</b> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: \* = 2. Playground, Equipment & Athletic Fields

**General Comments**

No General Comments Available

Email Address(es): tmgutierrez@dadeschools.net;  
jware@dadeschools.net;  
jaybolton@dadeschools.net;  
ipalacio@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

Violation #18. Drinking Fountains  
Increase water pressure for all water fountains throughout the school.  
CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Manuel Alzugaray (27431)  
Inspector Contact Number: Work: (786) 216-9760 ex.  
Print Client Name:  
Date: 3/1/2019

Inspector Signature:

Handwritten signature of Manuel Alzugaray.

Client Signature:

Handwritten signature of the client.